

To,

Sub: Request for quotation for "Water Chilling Unit".

Dear Sir,

We (PDPM Indian Institute of Information Technology, Design and Manufacturing Jabalpur) are interested in the purchase of Water Chilling Unit.

Detailed specifications are attached in the Annexure 'A'.

Following terms and conditions apply:

1. Show all charges clearly, no hidden cost.
2. Show transportation charges/delivery to PDPM-IIITDM Jabalpur, Madhya Pradesh.
3. Price quoted should be inclusive of all applicable taxes and levies. Taxes, transportations should be clearly mentioned in the quotation.
4. The rates should be F. O. R. PDPM-IIITDM-Jabalpur, Mehgawan, Dumna Airport Road, Post: Khamaria, Jabalpur.
5. Attach all necessary documents, technical literature and catalogues.
6. Institute reserves the right to change the quantity as per its requirement at any stage. Further the Institute reserves the right to place order either of all the items or only some of the above items. The supplier shall have no right to claim any compensation in such case.
7. The supplier is to submit earnest money deposit of Rs 5,000/- (Five thousand only) with their sealed quotation. Quotations without earnest money deposit shall be summarily rejected.
8. The Earnest money deposit should be a FDR or demand draft in favour of Director, PDPM- IIITDM.
9. Validity of quotation should be minimum 30 days.
10. Delivery should be within 15 days from the date of receipt of firm order.
11. In case of delay, penalty at the rate of 0.5% per day of the ordered value shall be charged (maximum penalty up to 7.5 % of the order value can be deducted). If the delay is more than two weeks the order shall stand cancelled and the earnest money deposit shall be forfeited.

12. Sealed quotation should reach on or before 01.00 pm on 22/02/2010, to the Deputy Registrar, PDPM-IIITDM Jabalpur, Dumna Airport Road, Post: Khamaria, Jabalpur (M.P.) Pin-482005.
13. Quotations will be opened on the same day (on 22/02/2010) at 03:00 pm.
14. All disputes should be within the jurisdiction of Jabalpur.

You are requested to submit the sealed pack quotation with best offer for any one or more of the above mentioned items latest by February 22, 2010 at the following address:

The Deputy Registrar,
PDPM Indian Institute of Information Technology
Design & Manufacturing, Jabalpur
Dumna Airport Road,
Post: Khamaria
Jabalpur - 482005

Send the sealed pack quotation by post/courier. Mention the reference no IIITDM/DR/2009-10/02/701 at the top of the envelope.

Mr. Raghunath Bhattacharya
Deputy Registrar

ANNEXURE 'A'
SPECIFICATION FOR CHILLING UNIT

Two channel Water Chilling unit with S.S. Balancing Tank

Outer Cabinet made of PPGI Sheet.

Output Temperature & Cooling capacity

- i) One at 3000 Ltr/Hr at 25°C at 3 to 4 bar pressure. This water needs to be re-circulated. The temperature gradient may be 10°C
- ii) Second 720 Ltr/Hr at 4°C at 3.5 to 7.0 bar pressure. This water can not be re-circulated.

Water Quality Requirement: PPM < 250 &
pH - 7.2 to 8.0

Complete with Following:

1. Compressor 415 V/3PH/50Hz
2. Air Cooled Condenser with Axial Fan
3. PHE 2.0 TR (Brazed Type Plate Heat Exchanger)
4. HP/LP Cutout Switch
5. Filter Drier
6. Expansion Valve
7. Chilled water circulation Pump of required capacity
8. Digital Temperature Controller
9. Y-type strainer on water outlet

Mr. Raghunath Bhattacharya
Deputy Registrar