

# PDPM IIITDM JABALPUR

## Schedule of Quantities

**Name of work: Annual Maintenance of water purifier for LHTC Building at IIITDM Jabalpur.**

Sl. No.	Description	Unit	Qty.	Rate (In figure & words)	Amount (In figure & words)
NS-1	1) You will be required to ensure monthly inspection/Servicing of water purifier during the first week of every month and which shall be done by your authorised representative. 2) Complete inspection /service of the Water purifier shall be carried out every month. 3) The AMC shall cover replacement of membrane, Pump, Control panel, flow meter, pressure gauge, S.V(solenoid Valve), LPS(Low Pressure system), Raw water Pump, Multigrade media filter , Activated carbon Filter, UV (ultra Violet)lamp whenever required during the AMC period so as to achieve the desired quality of filtered water. 4) Cleaning of the membrane shall be done whenever required. 5) The complaint shall required to be attended within 24 hours after information conveyed to the firm through suitable mode of communication In case of failure repairs shall be made by the Institute thorough some other agency, on your cost. 6) All the Parameters as required to ensure pure potable water shall be checked during monthly inspection. 7) Inspection report and general suggestions regarding maintenance of the equipments shall be provided to us after every inspection. 8) The work shall be carried out in the presence of our representatives. 9) The TDS in water shall be maintained maximum up to 100. 10) Dismantled item which shall be replaced during the AMC shall be to the kept on standby arrangement	Yearly	1		
<b>Total Amount</b>					