

(An Institute of National Importance Established by an Act of Parliament)

Τo,

Date- 02.07.2025

Subject – Quotation for 1 no 20 KVA UPS with 3 phase input voltage and 3 phase output voltage with a backup time of 30 minutes

Dear Sir/madam,

Our Institute requires 1 no 20 KVA UPS with 3 phase input voltage and 3 phase output voltage with a backup time of 30 minutes

Required Specification-

- 1. UPS type- 20 KVA Online UPS (Pure Sine wave 50 Hz) with battery
- 2. Qnt-1 no
- 3. UPS brand- Numeric, APC, Microteck, Luminious
- 4. Backup time 30 mints
- 5. Input voltage- 3 phase 415 volt along with tolerance at input +/- 10%
- 6. Output voltage 3 phase 415 Volt with maximum tolerance at the output +/- 5%
- 7. Warranty of UPS 2 years and above
- 8. Warranty of battery 2 years and above
- 9. Battery type- SMF
- 10. Battery Brand Exide, Luminious, Tata Green, Amaron, Okaya
- 11. Scope of work- Supply and installation of UPS with including all accessories like battery trolley (MS material, powder coating), cables (branded copper cable with at least 50% overload capacity), connectors etc

You are requested to provide your quotation to the undersigned within 7 days from the date of receive of this letter with below terms-

- 1. Rate should include GST, transportation, supply, testing & commissioning
- Work order will be provided to the L1 agency for the work and Payment will be done within 15 days from the date of commissioning
- 3. No advance payment will be done to the agencies
- 4. Quotation and bill should be made in the name of institute only.
- 5. The work should be completed within 15 days from the date of receive of work order.

JE(Electrical)





डुमना विमानतल मार्ग, जबलपुर–482005, म.प्र. शासन Dumna Airport Road, Jabalpur - 482005, M.P. India Ph. : +91-761-2794065, Fax : +91-761-2794094 Website : www.iiitdmj.ac.in